


UDC Lab Free Cooling		
OAT On Sp	21.0 °C	Status ●
RACU11 Mixed Air Temp	21.0 °C	
RACU11 Supply Damper	100 %	
RACU12 Mixed Air Temp	21.0 °C	
RACU12 Supply Damper	100 %	

LV Room Free Cooling		Status ●
Mixed Air Temp	21.0 °C	
Mixing Damper	100 %	



Navigator




Alarms

# Ground Floor Plan

Devices | Default

16:10 01/05/15 Outside Air wait °C

- Navigation
  - Ground Floor Plan
  - Computer Room 1
  - Computer Room 2
  - Computer Room 3
  - Telecomms Room/Print Store
  - Plant Rooms
  - Power Building
- 
- Sub Menu
  - Plant Menus



BMS Innovations

# Computer Room 1

Navigation

- Ground Floor Plan
- 1st Floor Plan
- Computer Room 1
- Computer Room 2 & 3/Tape Library
- Bridge / Telecomms Room
- Red UPS/Battery Room
- White UPS/Battery Room
- Grey UPS/Battery Room
- Green UPS/Battery Room

Inergen Makeup Extract


Alarms | Floor Plan | Devices | Default | 10:36 | 01/05/15 | Outside Air 21.0 °C

ChW System 1 Information

Flow Temp	21.0 °C
Return Temp	21.0 °C
Chiller 1A Running	<input checked="" type="checkbox"/>
Chiller 1A Common Fault	<input type="checkbox"/>

ChW System 2 Information

Flow Temp	21.0 °C
Return Temp	21.0 °C
Chiller 2A Running	<input checked="" type="checkbox"/>
Chiller 2A Common Fault	<input type="checkbox"/>



Sub Menu

- Plant Menus



# Computer Room 1

Navigator


Alarms CRAC1 Devices 11:33 01/11/12 Outside Air 21.0 °C

**Navigation**

- Ground Floor Plan
- Computer Room 1
  - CRAC1
  - CRAC2
  - CRAC3
  - CRAC4
  - CRAC5
  - CRAC6
  - CRAC7
  - CRAC8
  - CRAC9
  - CRAC10

**Sub Menu**

- Plant Menus



**CRAC Information**

BMS Enable	●
Temperature Setpoint	21.0 °C
Humidity Setpoint	21.0 %RH
Alarm Reset	Reset
Overtemp Cutout	●
Bottle Change	●
Common Alarm	●
Auxiliary Alarm	●

**Chiller Information**

BMS Enable	Enable
Alarm Reset	Reset
Non Critical Alarm	●
Critical Alarm	●
Evaporator Flow Switch	●
Evaporator Flow Alarm	●
Serious Flow Alarm	●
Emergency Stop	●
Comms Failure	●
Freeze Protection	●
MCCB Alarm	●
ChW Pump Duty	Duty-P2
ChW Pump Fault Reset	Resetting

**Chiller - Circuit 1 Information**

Circuit 1 Alarm	●
Compressor 1 Running	●
Compressor 2 Running	●
Circuit 1 Low Pressure	●
Compressor 1 Alarm	●
Compressor 2 Alarm	●
Differential Pressure	●
Liquid Pressure	21.0 Bar
CP1 Hours Run Low	25.5 Hrs
CP1 Hours Run High	100.0 Hrs
CP2 Hours Run Low	24.0 Hrs
CP2 Hours Run High	153.0 Hrs

**Chiller - Circuit 2 Information**

Circuit 1 Alarm	○
Compressor 3 Running	●
Compressor 4 Running	●
Circuit 2 Low Pressure	●
Compressor 3 Alarm	○
Compressor 4 Alarm	○
Differential Pressure	○
Liquid Pressure	21.0 Bar
CP3 Hours Run Low	21.0 Hrs
CP3 Hours Run High	21.0 Hrs
CP4 Hours Run Low	21.0 Hrs
CP4 Hours Run High	21.0 Hrs

### Data Centre Overview

- Overview
- Generator
- Data Centre**
- Protection
- UPS
- Cooling

**PDU A**

BREAKER	<input type="checkbox"/>
SURGE	<span style="color: red;">ALARM</span>
AMPS	
PHASE 1	21.0
PHASE 2	21.0
PHASE 3	21.0
TOTAL	21.0

**PDU B**

BREAKER	<span style="color: green;">ON</span>
SURGE	<span style="color: green;">OK</span>
AMPS	
PHASE 1	21.0
PHASE 2	21.0
PHASE 3	21.0
TOTAL	21.0

AHU 04  
 DC DOOR AUTO

AHU 05  
 DC FIRE DOOR ALARM

	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
05																			
04																			
03																			
02	42	41	40	39	38	37	36	35	34	33	32	31	30	29	28	27	26	25	24
01																			

RACK LAYOUT

RACK	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21
BREAKER	1	1	1	2	2	2	3	3	3	4	4	4	5	5	5	6	6	6	7	7	7
PHASE	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3
<span style="background-color: red; color: white;">A</span> AMPS	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0
<span style="background-color: blue; color: white;">B</span> AMPS	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0

RACK	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42
BREAKER	8	8	8	9	9	9	10	10	10	11	11	11	12	12	12	13	13	13	14	14	14
PHASE	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3
<span style="background-color: red; color: white;">A</span> AMPS	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0
<span style="background-color: blue; color: white;">B</span> AMPS	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0	21.0

### Data Centre Rack 01 - Breaker 1 Phase 1

- Overview
- Generator
- Data Centre**
- Protection
- UPS
- Cooling

PDU A	UNIT	PHASE 1
CURRENT	AMPS	21.0
VOLTAGE	VOLTS	230
REAL POWER	kW	21.0
APPARENT POWER	kVA	21.0
REACTIVE POWER	kVAr	21
REAL ENERGY	kWh	21.0
POWER FACTOR	PF	21.0
FREQUENCY	HZ	21.0
PDU SUPPLY CAPACITY	AMPS	21.0
PDU CAPACITY USED	%	21.0
PDU CAPACITY FREE	AMPS	21.0
PDU CAPACITY FREE	%	21.0



PDU B	UNIT	PHASE 1
CURRENT	AMPS	21.0
VOLTAGE	VOLTS	21
REAL POWER	kW	21.0
APPARENT POWER	kVA	21.0
REACTIVE POWER	kVAr	21
REAL ENERGY	kWh	21.0
POWER FACTOR	PF	21.0
FREQUENCY	HZ	21.0
PDU SUPPLY CAPACITY	AMPS	21.0
PDU CAPACITY USED	%	21.0
PDU CAPACITY FREE	AMPS	21.0
PDU CAPACITY FREE	%	21.0

Live graph logging data

Live graph logging data


BMS Innovations

### Denco AHU4

OS11

- Overview
- Generator
- Data Centre**
- Protection
- UPS
- Cooling

	UNIT	
CONTROL TEMPERATURE	DegC	321.7
CONTROL HUMIDITY	%RH	21.0
RETURN AIR TEMPERATURE	DegC	21.0
RETURN AIR HUMIDITY	%RH	21.0
COOLING DEMAND	%	21.0
HEATING DEMAND	%	21.0
HUMIDITY DEMAND	%	21.0
DEHUM DEMAND	%	21.0
AMBICOOL DEMAND	%	21.0
SUPPLY AIR TEMPERATURE	DegC	21.0
WATER TEMPERATURE	DegC	21.0
CONDENSING PRESSURE 1	Bar	21.0
CONDENSING PRESSURE 2	Bar	21.0
TEMPERATURE SETPOINT	DegC	21.0
HUMIDITY SETPOINT	%RH	21.0



FAN STATUS	<b>OFF</b>
CRITICAL ALARM STATUS	<b>OK</b>
MAINTENANCE ALARM STATUS	<b>ALARM</b>
RETURN AIR TEMP SENSOR FAIL	<b>ALARM</b>
RETURN AIR HUMIDITY SENSOR FAIL	<b>ALARM</b>
PRESSURE 1 SENSOR FAIL	<b>ALARM</b>
PRESSURE 2 SENSOR FAIL	<b>ALARM</b>
WATER TEMP SENSOR FAIL	<b>ALARM</b>
SUPPLY AIR TEMP SENSOR FAIL	<b>ALARM</b>
SUPPLY AIR HUMIDITY SENSOR FAIL	<b>ALARM</b>
AIR FLOW FAIL ALARM	<b>ALARM</b>
FILTER BLOCKED ALARM	<b>ALARM</b>
WATER DETECTION ALARM	<b>ALARM</b>
AUXILLARY ALARM	<b>ALARM</b>
HIGH CONTROL TEMP ALARM	<b>ALARM</b>
LOW CONTROL TEMP ALARM	<b>ALARM</b>
HIGH CONTROL HUMIDITY ALARM	<b>ALARM</b>
LOW CONTROL HUMIDITY ALARM	<b>ALARM</b>
LOW SUPPLY TEMP ALARM	<b>ALARM</b>
HIGH SUPPLY HUMIDITY ALARM	<b>ALARM</b>
SIP COMMS FAIL	<b>ALARM</b>

BMS Innovations